

## Classification Report

Number	17-003487-PR01 (NW-E01-02-en-01)
Owner	GS S.A. Mosquito nets, Folding doors and Shower boxes Kalamakiou Str. 70 Industrial Area 17455 Alimos, Athens Greece
Product	Zip awning with fly screen
Designation	System: Cronos motorized
Details	Manufacturer GS S.A., Mosquito nets, Folding doors and Shower boxes - Alimos, Athens; Material screen Vinyl coated polyester mesh; Overall dimensions (W x H) 3500 mm x 2200 mm
Special features	

### Result

Resistance to wind loads according to EN 13561-2004-09+A1:2008-10



**W<sub>3500</sub> x H<sub>2200</sub> Class: 3**

Non-harmonized version at the time of testing –

Resistance to wind loads according to EN 13561-2015-05 + AC:2016-03



**W<sub>3500</sub> x H<sub>2200</sub> Class: 6**

### Basis \*)

EN 13561-2004-09+A1:2008-10  
EN 13561-2015-05 + AC:2016-03  
\*) and corresponding national versions  
e.g. DIN EN)

Test report: 17-003487-PR01 PB-E01-02-en-01

### Representation



### Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

### Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

30.01.2018



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Peter Marquardt, Dipl.-Ing. (FH)  
Operating Testing Officer  
Building Component Testing

Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 0D3-0D25F